



Inspection and Technical Services

Gas Equipment Bulletin: Clarification of Appliance Vent Termination

ITS 21-011

B149.1 code allows an appliance vent to terminate directly over the center-line of a regulator providing that the appliance vent terminates at a height of 15 feet or more above the meter/regulator assembly.

However, moisture in flue products may condense at the outlet of the vent in cold weather and there is potential for this condensation to drip down onto and interfere with a regulator installed directly below.

Therefore, in Manitoba, an appliance vent must **NEVER** terminate within 3 feet (900 mm) horizontally of the vertical center of the regulator vent outlet.

Figure (A) Clarification of 8.14.8 (e), (d)

